

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

CB TEST CERTIFICATE

Product	Photovoltaic (PV) Module(s)
Name and address of the applicant	GANCO ENERGY INDIA PRIVATE LIMITED SY. NO: 122/1 - 14, DEKKATIPALEM, NEAR BANK COLONY, BHEEMUNIPATNAM, VISAKHAPATNAM - 531163, ANDHRA PRADESH, INDIA
Name and address of the manufacturer	GANCO ENERGY INDIA PRIVATE LIMITED SY. NO: 122/1 - 14, DEKKATIPALEM, NEAR BANK COLONY, BHEEMUNIPATNAM, VISAKHAPATNAM - 531163, ANDHRA PRADESH, INDIA
Name and address of the factory	GANCO ENERGY INDIA PRIVATE LIMITED SY. NO: 122/1 - 14, DEKKATIPALEM, NEAR BANK COLONY, BHEEMUNIPATNAM, VISAKHAPATNAM - 531163, ANDHRA PRADESH, INDIA
Note: <i>When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Page 2
Trademark (if any)	
Type of Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	72 Cell Series: GE-72P-320Wp, GE-72P-315Wp, GE-72P-310Wp, GE-72P-305Wp, GE-72P-300Wp, See Page 2
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to EN 61215: 2005 <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61215:2005
As shown in the Test Report Ref. No. which forms part of this Certificate	NC29231-4788466866.2.1-D1 issued on 2019-02-16

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

Date: 2019-02-25

Signature:

Jolanta M. Wroblewska

For full legal entity names see www.ul.com/ncbnames



Ref. Certif. No.

US-33276-UL

Model Details:
 60 Cell Series:
 GE-60P-270Wp, GE-60P-265Wp, GE-60P-260Wp, GE-60P-255Wp, GE-60P-250Wp
 36 Cell Series:
 GE-36P-160Wp, GE-36P-155Wp, GE-36P-150Wp, GE-36P-145Wp, GE-36P-140Wp

Ratings:
 72, 60 Cell Series:
 Maximum System Voltage: 1500V
 Maximum over current protection rating: 15A
 36 Cell Series:
 Maximum System Voltage: 1000V
 Maximum over current protection rating: 10A

See specific model rating in Test Report - General Product information

Additional information (if necessary)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-02-25

Signature: Jolanta M. Wroblewska



Ref. Certif. No.

US-33277-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Photovoltaic (PV) Module(s)
Name and address of the applicant	GANCO ENERGY INDIA PRIVATE LIMITED SY. NO: 122/1 - 14, DEKKATIPALEM, NEAR BANK COLONY, BHEEMUNIPATNAM, VISAKHAPATNAM - 531163, ANDHRA PRADESH, INDIA
Name and address of the manufacturer	GANCO ENERGY INDIA PRIVATE LIMITED SY. NO: 122/1 - 14, DEKKATIPALEM, NEAR BANK COLONY, BHEEMUNIPATNAM, VISAKHAPATNAM - 531163, ANDHRA PRADESH, INDIA
Name and address of the factory	GANCO ENERGY INDIA PRIVATE LIMITED SY. NO: 122/1 - 14, DEKKATIPALEM, NEAR BANK COLONY, BHEEMUNIPATNAM, VISAKHAPATNAM - 531163, ANDHRA PRADESH, INDIA
Note: <i>When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Page 2
Trademark (if any)	
Type of Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	72 Cell Series: GE-72P-320Wp, GE-72P-315Wp, GE-72P-310Wp, GE-72P-305Wp, GE-72P-300Wp, See Page 2
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to EN 61730-1:2007 / A1:2012 / A2:2013 / A11:2014 and EN 61730-2:2007 / A1:2012 <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61730-1:2004/AMD1:2011, IEC 61730-1:2004/AMD2:2013, IEC 61730-1:2004, IEC 61730-2:2004/AMD1:2011, IEC 61730-2:2004
As shown in the Test Report Ref. No. which forms part of this Certificate	NC29231-4788466866.2.1-D2 issued on 2019-02-16

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

Date: 2019-02-25

Signature:

Jolanta M. Wroblewska

For full legal entity names see www.ul.com/ncbnames



Ref. Certif. No.

US-33277-UL

Model Details:

60 Cell Series:

GE-60P-270Wp, GE-60P-265Wp, GE-60P-260Wp, GE-60P-255Wp, GE-60P-250Wp

36 Cell Series:

GE-36P-160Wp, GE-36P-155Wp, GE-36P-150Wp, GE-36P-145Wp, GE-36P-140Wp

Ratings:

72, 60 Cell Series:

Maximum System Voltage: 1500V

Maximum over current protection rating: 15A

36 Cell Series:

Maximum System Voltage: 1000V

Maximum over current protection rating: 10A

See specific model rating in Test Report - General Product information

Additional information (if necessary)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-02-25

Signature:

Jolanta M. Wroblewska